

GENERAL INFORMATION

Miami County has a current unconditional license to operate its Public Water System issued by the OEPA on January 1, 2016. This report is a requirement of the Safe Drinking Water Act Amendments of 1996.

This water quality report is for the year 2015.

WATER SOURCE INFORMATION

The Miami County Sanitary Engineering Department serves you with water we purchase from the Clark County, Ohio water plant located at Medway Water Treatment Plant. Clark County obtains its public drinking water supply from buried valley sand and gravel aquifers associated with the Great Miami River. Clark County currently utilizes three (3) production wells to draw water from the aquifer. Well water is pumped to the distribution system and chlorine is added to disinfect the water prior to being pumped to you, the consumer. Miami County water meets or exceeds all the standards that are set forth by the Ohio and United States Environmental Protection Agencies.

ADDITIONAL INFORMATION

For more information on your drinking water please contact Jeff Shields, Water and Wastewater Superintendent at the Miami County Sanitary Engineering Department at 937-440-5653 or see www.miamicountyohio.gov. Public participation and comments are encouraged by contacting MCSED, or the Board of Miami County Commissioners located in the Miami County Safety Building, Troy, Ohio.


E.P.A Requirements

The OEPA requires regular sampling to ensure drinking water safety. Chlorine and bacteria sampling is performed on a regular routine basis, while tests for lead and copper and other contaminants are performed on a specified schedule in accordance with EPA regulations.

WHO NEEDS TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800) 426-4791.

Troy, Ohio 45373
2200 N. CR 25A
Miami County Sanitary Engineer



2016 Drinking Water Quality Consumer Confidence Report for Miami County Bethel Township Public Water Systems OH5502703

INTRODUCTION

Miami County Sanitary Engineering Department (MCSED) has prepared this report to provide information to you, the consumer, on the quality of our drinking water. This report includes general health information, water quality test results, water source and contact information.

Miami County Sanitary Engineering Department
2200 N. CR 25A
Troy, Ohio 45373
Office Hours:
Monday-Friday 8:00 a.m. to 5:00 p.m.
Phone:
937-440-5653

Sanitary Engineer Paul P. Huelskamp, P.E.,P.S.

DEFINITIONS OF TERMS AND ABBREVIATIONS USED IN THIS REPORT:

Maximum Contamination Level (MCL): The highest level of contamination that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.

MCLG's are set by the USEPA and allow for a significant margin of safety.

Not Regulated (N.R.): USEPA has not established a MCL or MCLG.

Parts per Million (ppm) or Milligrams per Liter (mg/L): Units of measure for concentration of a contaminant. One part of a substance in one million parts of a substance.

Parts per Billion (ppb) or Micrograms per Liter (ug/L): Units of measure for concentration of a contaminant. One part of a substance in one billion parts of a substance.

Action Level: The concentrations of a contaminant that triggers the public water system to install other treatment technologies to reduce the concentration of the contaminant.

PicoCuries per liter: a measure of radioactivity in water.

Water Quality Results

Substance	Highest Level Detected	Range of Detections	Highest Level Allowed (MCL)	Ideal Goals (MCLG)	Violations	Year Samples	Sources of Substances
Fluoride	1.07 ppm	0.67-1.53 ppm	4 ppm	4 ppm	None	2015	Erosion of Natural Deposits
Total Chlorine	1.7 ppm	0.3-1.7 ppm	4 ppm	4 ppm	None	2015	Water Disinfection
Total Coliform	0 ppm		1 positive/month		None	2015	Naturally Present in the Environment
Nitrate	1.58 ppm	1.58 ppm	10 ppm	10 ppm	None	2015	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Regulated at the Customer's Tap

			Action Level				
Lead	<5 ppb	<5 ppb	15.5 ppb	0 ppb	None	2014	Household Plumbing
Copper	109.9 ppb	64.8-109.9 ppb	1350 ppb	1300 ppb	None	2014	Household Plumbing

**See Special Comments

Regulated in the Distribution System

Total Trihalomethane	35.03 ppb	N/A	80 ppb	0 ppb	None	2015	By-Product of Drinking Water Chlorination
Haloacetic Acids	<6 ppb	N/A	60 ppb	N/A	None	2015	By-Product of Drinking Water Chlorination

Unregulated Contaminants

Bromodichloromethane	12.30 ppb	N/A	N.R.	N.R.	None	2015	Components of Total Trihalomethanes
Bromoform	2.25 ppb	N/A	N.R.	N.R.	None	2015	
Chloroform	11.50 ppb	N/A	N.R.	N.R.	None	2015	
Dibromochloromethane	8.98 ppb	N/A	N.R.	N.R.	None	2015	

Special Comments

**This report lists the highest recorded concentrations of contaminants measured in 2014. The listed concentration for Copper during 2014 was 109.9 ppb. This sample was one of 5 samples collected from residential users to comply with annual reduced monitoring Lead and Copper Rule Requirements. The 90th percentile concentration for Copper was 108.05 ppb. The number of sites above the action level = 0. Copper and Lead sampling will be collected again in 2017.

What are the sources of contaminants in drinking water?

The sources of drinking water, both tap and bottled water, includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity; (farming, septic tanks, lawn chemical, storm runoff, etc.)

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk unless the contaminant level exceeds the MCL established by the USEPA. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Hotline (800-426-4791).

Lead Education

"If presence, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Miami County Bethel Township PWS is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Hotline at 800-426-4791 or at <http://www.epa.gov/safewater/lead>."